Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WS573

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BENET, JAMES			Phone #
Mailing Address: 19168 SHINES RD			
City: GLIDDEN	State: WI	Zip Code: 54527	
County: Ashland	Co. Permit #:	Notification #: 41118667	Completed: 07-22-2011

Well Constructor (Business Name): JEFFREY J HOLT	Lic. #: 5891	Facility ID # (Public Wells):	
Address: HOLT WELL DRILLING PARK FALLS WI 54552-1390		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of PEEKSVILLE

Fire # (if avail.)

Street Address or Road Name and Number
SHINES RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

SW	SE	Section	Township	Range
or Govt Lot #		20	42 N	1 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	56

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	10
-	-	P	-	HARD PAN	10	50
-	-	G	-	GRAVEL	50	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B PE IPSCO	Surface	56
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUND

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANNULAR BENTONITE	Surface		

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 9 GP M for 10 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJH		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		25

Comment:

Created On: 11-15-2011 Updated On: 11-15-2011 Review Status: