

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WT997		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner CHESMORE, NICHOLAS						Phone # (608)719-9159		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 81						Town of IRON RIVER						64870									
City IRON RIVER						State WI		Zip Code 54847				Street Address or Road Name and Number KICK IN BACK TRL									
County Bayfield		Co. Permit #		Notification # 6842562501		Completed 06-10-2017		Subdivision Name			Lot #		Block #								
Well Constructor (Business Name) WAYNE HOLLY				Lic. # 7218		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.51577 °N -91.3746 °W				Method Code GPS008									
Address WAYNE HOLLY WELL DRILLING IRON RIVER WI 54847				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 33 47 N 8 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
9		Surface		58		<u>Yes</u> Rotary - Mud Circulation <u>No</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T S S - SAND, TAN, SOFT T - G G ROCKS, GRAVEL, TAN R - S M SILTY, RED, SAND T A S - COARSE, TAN SAND				Surface 10 10 20 20 35 35 58							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				18 in. above grade							
5		PVC, SDR 21 AMERICON, GLUE ASTM-F4800				Surface		54		10. Pump Test Pumping level 45 ft. below surface Pumping at 8 GP M for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
3		JOHNSON STAINLESS, 10 SLOT				54		58													
7. Grout or Other Sealing Material Method PUMP														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? N/A							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
EZ-SEAL BENTONITE		Surface		50		7 S						13. Constructor / Supervisory Driller Lic # Date Signed WH 06-12-2017 Drill Rig Operator Lic or Reg # Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		9	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 07-13-2017

Updated On: 02-09-2023

Review Status: