

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WT998		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HEABERLIN, BRAD						Phone # (641)891-1546		1. Well Location				Fire # (if avail.)							
Mailing Address 2456 HWY 14						Town of TRIPP						7760							
City COLUMBIA						State IA		Zip Code 50057				Street Address or Road Name and Number							
County Bayfield						Co. Permit #		Notification # 6878885701				Completed 07-25-2017							
Well Constructor (Business Name) WAYNE HOLLY						Lic. # 7218		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.59108 °N -91.41538 °W							
Address WAYNE HOLLY WELL DRILLING IRON RIVER WI 54847						Well Plan Approval #		SE SW		Section 31		Township 48 N							
						Approval Date (mm-dd-yyyy)		Range 8 W		Method Code GPS008									
Hicap Permanent Well #						Common Well #		Specific Capacity 0.4				2. Well Type New Well							
3. Well serves 1 # of Private, potable						Hicap Well ? No		of previous unique well #				constructed in							
Heat Exchange ___ # of drillholes						Hicap Property ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE						5. Drillhole Dimensions and Construction Method						8. Geology							
Dia. (in.) 9		From (ft.) Surface		To (ft.) 120		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						Yes Rotary - Mud Circulation No						T - S - TAN, SAND		Surface		5			
						Rotary - Air						R - C - RED CLAY		5		55			
						Rotary - Air & Foam						T - S M TAN, SILTY SAND		55		60			
						Drill-Through Casing Hammer						T - P - TAN HARDPAN		60		114			
						Reverse Rotary						T E S - TAN, CLEAN SAND		114		120			
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen						9. Static Water Level						11. Well Is							
Dia. (in.) 5		Material, Weight, Specification PVC SDR21 AMERICAN, GLUE ASTM F4800				From (ft.) Surface		To (ft.) 116		8 ft. above ground surface				18 in. above grade					
Dia. (in.) 3		Screen type, material & slot size JOHNSON, STAINLESS, 10 SLOT				From (ft.) 116		To (ft.) 120		10. Pump Test				Developed ? Yes					
										Pumping level 20 ft. below surface				Disinfected ? Yes					
										Pumping at 10 GP M for 3 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?													
Method PUMP												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				N/A									
EZ-SEAL		Surface		110		12 S													
						13. Constructor / Supervisory Driller						Lic #		Date Signed					
						WH								08-07-2017					
						Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		33	Septic or Holding, or POWTS Tank		78

Comment: FLOWING

Created On: 08-21-2017

Updated On: 02-09-2023

Review Status: