Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WT998

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HEABERLIN, BRAD	Phone #: (641)891-1546
Mailing Address: 2456 HWY 14	
City: COLUMBIA	State: IA — Zip Code: 50057
County: Bayfield	Co. Permit #:
Notification #: 6878885701	Completed: 07-25-2017
Well Constructor (Business Name): WAYNE HOLLY	Lic. #: 7218
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: WAYNE HOLLY WELL DRILLING, IRON RIVER WI 54847	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.8	

1. Well Location

Town of TRIPP	Fire # (if avail.): 7760
Street Address or Road Name and Number: 7760 HOFFREN RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.59108 °N -91.41538 °W	Method Code: GPS008
SE SW or Govt Lot #:	Section: 31 — Township: 48 N — Range: 8 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	120

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	S	-	TAN, SAND	Surface	5
R	-	C	-	RED CLAY	5	55
T	-	S	M	TAN, SILTY SAND	55	60
T	-	P	-	TAN HARDPAN	60	114
T	E	S	-	TAN, CLEAN SAND	114	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC SDR21 AMERICAN, GLUE ASTM F4800	Surface	116
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	JOHNSON, STAINLESS, 10 SLOT	116	120

9. Static Water Level

8 ft. above ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 10 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ-SEAL	Surface	110	12 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH		08-07-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		33	Septic or Holding, or POWTS Tank		78

Comment: FLOWING

Created On: 08-21-2017 Updated On: 10-15-2026 Review Status: