Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WT999

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: GROVE, TONY	Phone #: (651)303-2146
Mailing Address: 1132 PARKWOOD LN	
City: STILLWATER	State: MN — Zip Code: 55082
County: Bayfield	Co. Permit #:
Notification #: 6903320101	Completed: 09-15-2017

1. Well Location

Town of PONT WING	Fire # (if avail.): 7345
Street Address or Road Name and Number: 7345 LANDON RD	
Subdivision Name	Lot # / Block #

Well Constructor (Business Name): WAYNE HOLLY	Lic. #: 7218	Facility ID # (Public Wells)	
Address: WAYNE HOLLY WELL DRILLING, IRON RIVER WI 54847		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7	

Latitude / Longitude in Decimal Degree (DD): 46.75983 °N -91.41897 °W				Method Code: GPS008
NE NW or Govt Lot #	Section: 6	Township: 49 N	Range: 8 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	40
6	40	50

Upper Enlarged Drillhole: Yes
Lower Open Bedrock: Yes

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - P -	TAN, HARD PAN	Surface	5
R - C -	RED CLAY	5	35
R - P -	RED, HARD PAN	35	40
R - N -	RED, SANDSTONE	40	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A-53-B NEW STEEL PIPE, WELD	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
13 ft. below ground surface

10. Pump Test
Pumping level 28 ft. below surface
Pumping at 10 GP M for 6 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ-SEAL BENTONITE	Surface	40	10 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH		10-04-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		21	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 10-18-2017 Updated On: 06-25-2020 Review Status: