

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WU082		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RUSSELL, WALT						Phone # (262)490-0252		1. Well Location				Fire # (if avail.)							
Mailing Address W868 CO RD CI						Town of MARION						W6945							
City PALMYRA						State WI		Zip Code 53156				Street Address or Road Name and Number							
IROGAMI TRAIL						Subdivision Name				Lot #		Block #							
County Waushara		Co. Permit #		Notification # 41609495		Completed 09-12-2011		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Well Constructor (Business Name)				Lic. # 538		Facility ID # (Public Wells)				44.0603 °N -89.2308 °W		GCD013							
Address JAKUBOWSKI WELL DRILLING WILD ROSE WI 54984				Well Plan Approval #		NW SE		Section 6		Township 18 N		Range 11 E							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4		2. Well Type Replacement				of previous unique well # constructed in							
3. Well serves 1 # of COTTAGE				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Driven Point		Heat Exchange ___ # of drillholes							
Private, potable				Hicap Property ? No		Hicap Potable ?				4. Potential Contamination Sources - ON REVERSE SIDE									
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
2		Surface		29		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 2in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - S -				SAND		Surface		29	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		13 ft. below ground surface				16 in. above grade					
2		T&C 115 WALL KOREAN 3.75 FT				Surface		26		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes					
1.25		STAIN STEEL 10 SLOT				26		29		Pumping at 10 GP M for 2 Hrs.				Capped ? Yes					
7. Grout or Other Sealing Material												Pumping Method ?				12. Notified Owner of need to fill & seal ?			
Method												Filled & Sealed Well(s) as needed?				Yes			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
Surface				Surface		Surface		Surface		MJ				09-19-2011		Drill Rig Operator			
Surface				Surface		Surface		Surface		Lic or Reg #				Date Signed		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Building Overhang		5
			Collector Sewer - San or Storm		150

Comment:

Created On: 10-19-2011

Updated On: 05-05-2020

Review Status: