Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WU082

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RUSSELL, WALT	Phone #: (262)490-0252
Mailing Address: W868 CO RD CI	
City: PALMYRA	State: WI — Zip Code: 53156
County: Waushara	Co. Permit #:
Notification #: 41609495	Completed: 09-12-2011
Well Constructor (Business Name): MICHAEL J JAKUBOWSKI	Lic. #: 538
Facility ID # (Public Wells):	
Address: JAKUBOWSKI WELL DRILLING, WILD ROSE WI 54984	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.4	

1. Well Location

Town of MARION	Fire # (if avail.): W6945
Street Address or Road Name and Number: IROGAMI TRAIL	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.0603 °N -89.2308 °W	Method Code: GCD013
NW SE or Govt Lot #:	Section: 6 — Township: 18 N — Range: 11 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

3. Well serves 1 # of COTTAGE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	29

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 2in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - S -	SAND	Surface	29

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	T&C 115 WALL KOREAN 3.75 FT	Surface	26
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	STAIN STEEL 10 SLOT	26	29

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		09-19-2011
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Building Overhang		5
			Collector Sewer - San or Storm		150

Comment:

Created On: 10-19-2011 Updated On: 05-05-2020 Review Status: