

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WU864		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner STEIN, DAVID						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 2225 HWY S						Town of HERMAN						2225							
City IRON RIDGE						State WI		Zip Code 53035				Street Address or Road Name and Number 2225 HWY S							
County Dodge		Co. Permit #		Notification # 45417094		Completed 09-20-2012		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) KLEMME BROS WELL & PUMP INC				Lic. # 5935		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.38407 °N -88.50582 °W				Method Code OTH001					
Address 4932 HWY H KEWASKUM WI 53040				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 31 11 N 17 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.) 6		From (ft.) Surface		To (ft.) 200		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - X G CLAY SAND & GRAVEL - - C S SANDY CLAY - - C - CLAY - - H - SHALE I - L - LIMESTONE (WHITE) - - L H LIMESTONE & SHALE - - H - SHALE G - L - LIMESTONE GRAY		Surface 45 45 58 70 70 87 87 100 100 125 125 160 160 200		45 58 70 87 100 125 160 200					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.) 6		Material, Weight, Specification IPSCO ASTM A53B WELDED				From (ft.) Surface		To (ft.) 87		80 ft. below ground surface				14 in. above grade					
5		IPSCO ASTM A53B				87		160		Pumping level 87 ft. below surface				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 15 GP M for 8 Hrs.				Disinfected ? Yes					
										Pumping Method ?				Capped ? Yes					
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method MOUNDED												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material BENTONITE #8				From (ft.) Surface		To (ft.)		# Sacks Cement 3 S		13. Constructor / Supervisory Driller				Lic #		Date Signed			
										GK						10-10-2012			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		170	Downspout/Yard Hydrant		30
Building Drain - Sanitary		40	Foundation Drain to Clearwater		30
Building Overhang		30	Sewer - Building Sanitary		80
Clearwater Sump		40	Septic or Holding, or POWTS Tank		150

Comment:

Created On: 11-01-2012

Updated On: 09-08-2022

Review Status: