Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WU865

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PUNZENBERGER, RYAN & JILL	Phone #
Mailing Address: 4247 HACKER DR	
City: WEST BEND	State: WI — Zip Code: 53095
County: Washington	Co. Permit #: — Notification #: 45611072 — Completed: 09-21-2012
Well Constructor (Business Name): KLEMME BROS WELL & PUMP INC	Lic. #: 5935 — Facility ID # (Public Wells):
Address: 4932 HWY H, KEWASKUM WI 53040	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.2

1. Well Location

Town of WEST BEND	Fire # (if avail.): 4247
Street Address or Road Name and Number: 4247 HACKER DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.4043 °N -88.2482 °W	Method Code: GCD013
NW SE or Govt Lot #:	Section: 20 — Township: 11 N — Range: 19 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	118

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	X	G	CLAY SAND GRAVEL	Surface	25
-	-	Y	-	SAND & GRAVEL	25	58
-	-	C	-	CLAY	58	77
-	-	X	G	CLAY SAND & GRAVEL	77	115
-	-	Y	-	SAND & GRAVEL	115	118

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53B WELDED	Surface	116
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	.015 SLOTTED STAINLESS WELDED K PACKER	116	118

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE #8	Surface		2 S

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 30 GP for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GK		10-20-2012
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100
Building Drain - Sanitary		40
Building Overhang		30
Clearwater Sump		30

Type	Qualifier	Distance
Downspout/Yard Hydrant		30
Foundation Drain to Clearwater		30
Sewer - Building Sanitary		60
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 11-01-2012 Updated On: 07-05-2019 Review Status: