

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WU865		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner PUNZENBERGER, RYAN & JILL						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 4247 HACKER DR						Town of WEST BEND						4247									
City WEST BEND						State WI		Zip Code 53095				Street Address or Road Name and Number 4247 HACKER DR									
County Washington		Co. Permit #		Notification # 45611072		Completed 09-21-2012		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) KLEMME BROS WELL & PUMP INC				Lic. # 5935		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4043 °N -88.2482 °W				Method Code GCD013							
Address 4932 HWY H KEWASKUM WI 53040				Well Plan Approval #		NW SE		Section 20		Township 11 N		Range 19 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #				Common Well #		Specific Capacity 1.2				2. Well Type New Well											
Reason for replaced or reconstructed well ?																					
3. Well serves 1 # of				Hicap Well ? No		Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		118		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								- - X G		CLAY SAND GRAVEL		Surface		25	
														- - Y -		SAND & GRAVEL		25		58	
														- - C -		CLAY		58		77	
														- - X G		CLAY SAND & GRAVEL		77		115	
														- - Y -		SAND & GRAVEL		115		118	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				18 in. above grade							
6		IPSCO ASTM A53B WELDED				Surface		116		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface				Disinfected ? Yes							
5		.015 SLOTTED STAINLESS WELDED K PACKER				116		118		Pumping at 30 GP for 1 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method MOUNDED														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
BENTONITE #8				Surface				2 S		GK						10-20-2012					
										Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Downspout/Yard Hydrant		30
Building Drain - Sanitary		40	Foundation Drain to Clearwater		30
Building Overhang		30	Sewer - Building Sanitary		60
Clearwater Sump		30	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 11-01-2012

Updated On: 07-05-2019

Review Status: