Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WU866

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RAUCH, GARY & ELLEN	Phone #
Mailing Address: 8456 LINDEN RIDGE	
City: ALLENTON	State: WI — Zip Code: 53002
County: Washington	Co. Permit #: — Notification #: 45649745 — Completed: 09-26-2012
Well Constructor (Business Name): KLEMME BROS WELL & PUMP INC	Lic. #: 5935 — Facility ID # (Public Wells):
Address: 4932 HWY H, KEWASKUM WI 53040	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of WAYNE	Fire # (if avail.): 8456
Street Address or Road Name and Number: 8456 LINDEN RIDGE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.4956 °N -88.3291 °W	Method Code: GCD013
SW NE or Govt Lot #:	Section: 22 — Township: 12 N — Range: 18 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
8.75	20	41
6	41	140

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	X	G	CLAY SAND GRAVEL	Surface	12
T	-	L	-	LIMESTONE TAN	12	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53B WELDED	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

2 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 30 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADEN HEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	41	40 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GK		10-09-2012
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100
Building Drain - Sanitary		45
Building Overhang		15
Clearwater Sump		60

Type	Qualifier	Distance
Downspout/Yard Hydrant		15
Foundation Drain to Clearwater		15
Wastewater Sump		60
Sewer - Building Sanitary		60
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 12-13-2012 Updated On: 07-05-2019 Review Status: