Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WU867

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARX, PETER	Phone #
Mailing Address: 2530 RIDGE RD	
City: KEWASKUM	State: WI / Zip Code: 53040
County: Washington	Co. Permit #: / Notification #: 45676753 / Completed: 10-02-2012
Well Constructor (Business Name): KLEMME BROS WELL & PUMP INC	Lic. #: 5935 / Facility ID # (Public Wells):
Address: 4932 HWY H, KEWASKUM WI 53040	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity: 1

1. Well Location

Town of KEWASKUM	Fire # (if avail.): 2530
Street Address or Road Name and Number: 2530 RIDGE RD	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 43.4847 °N -88.1623 °W	Method Code: GCD013
SE SE or Govt Lot #:	Section: 24 / Township: 12 N / Range: 19 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	130

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	S	SANDY CLAY	Surface	25
-	-	C	-	CLAY	25	73
-	-	C	S	SANDY CLAY	73	86
-	-	S	-	SAND	86	120
-	-	Y	-	SAND & GRAVEL	120	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53B WELDED	Surface	130
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

59 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE #8	Surface		3 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GK		10-11-2012
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Foundation Drain to Clearwater		15
Building Overhang		15	Sewer - Building Sanitary		60
Downspout/Yard Hydrant		15	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 11-01-2012 Updated On: 07-05-2019 Review Status: