

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WU867		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MARX, PETER						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 2530 RIDGE RD						Town of KEWASKUM						2530					
City KEWASKUM						State WI		Zip Code 53040				Street Address or Road Name and Number 2530 RIDGE RD					
County Washington		Co. Permit #		Notification # 45676753		Completed 10-02-2012		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) KLEMME BROS WELL & PUMP INC				Lic. # 5935		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4847 °N -88.1623 °W				Method Code GCD013			
Address 4932 HWY H KEWASKUM WI 53040				Well Plan Approval #		SE SE		Section 24		Township 12 N		Range 19 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type New Well						of previous unique well #		constructed in			
3. Well serves # of				Hicap Well ?		Reason for replaced or reconstructed well ?											
Private, potable				Hicap Property ?													
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE														Construction Type Drilled			
5. Drillhole Dimensions and Construction Method										8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		130		Rotary - Mud Circulation				- - C S		SANDY CLAY		Surface		25	
						<u>Yes</u> Rotary - Air		<u>Yes</u>		- - C -		CLAY		25		73	
						Rotary - Air & Foam				- - C S		SANDY CLAY		73		86	
						Drill-Through Casing Hammer				- - S -		SAND		86		120	
						Reverse Rotary				- - Y -		SAND & GRAVEL		120		130	
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen										9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		59 ft. below ground surface				18 in. above grade			
6		IPSCO ASTM A53B WELDED				Surface		130		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes			
										Pumping at 20 GP for 2 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ?							
Method MOUNDED										Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
BENTONITE #8		Surface				3 S											
										13. Constructor / Supervisory Driller				Lic #		Date Signed	
										GK						10-11-2012	
										Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Foundation Drain to Clearwater		15
Building Overhang		15	Sewer - Building Sanitary		60
Downspout/Yard Hydrant		15	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 11-01-2012

Updated On: 07-05-2019

Review Status: