Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WU868

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WEINREICH, KIM | Phone #:

Mailing Address: 596 GRAND VIEW DR

City: FREDONIA | State: WI | Zip Code: 53021

County	Co. Permit #	Notification #	Completed
Washington		45791527	10-17-2012

Well Constructor (Business Name): GARY L KLEMME | Lic #: 257 | Facility ID # (Public Wells):

Address: KLEMME BROS WELL & PUMP INC, KEWASKUM WI 53040-9254

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.2

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of FARMINGTON | Fire # (if avail.): 596

Street Address or Road Name and Number: 596 GRAND VIEW DR

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): °N °W | Method Code

SE NE or Govt Lot # | Section: 23 | Township: 12 N | Range: 20 E

2. Well Type Reconstruction
of previous unique well # CU374 constructed in

Reason for replaced or reconstructed well ?
WELL WENT DRY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	220

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- No — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND GRAVEL	Surface	171
I	-	L	-	LIMESTONE WHITE	171	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53B WELDED	Surface	171
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING CUTTINGS	Surface		

9. Static Water Level
53 ft. below ground surface

10. Pump Test
Pumping level 140 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GK		10-25-2012
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Drain - Sanitary		30
Building Overhang		127

Type	Qualifier	Distance
Clearwater Sump		50
Foundation Drain to Clearwater		25
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 12-13-2012 Updated On: 03-26-2013 Review Status: