Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WV352

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PROFAB MACHINE			Phone #
Mailing Address: 791 190TH ST			
City: BALDWIN	State: WI	Zip Code: 54002	
County: St. Croix	Co. Permit #:	Notification #: 49520234	Completed: 10-15-2013

Well Constructor (Business Name): AUNE WELL DRILLING INC	Lic. #: 95	Facility ID # (Public Wells):	
Address: 1171 CNTY RD T HAMMOND WI 54015-4827		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

3. Well serves 1 # of SHOP
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of HAMMOND

Fire # (if avail.): 791

Street Address or Road Name and Number: 791 190TH ST

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 44.97677 °N -92.4148 °W
Method Code: GPS008

NW or Govt Lot #	NW	Section: 26	Township: 29 N	Range: 17 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	52
6	52	145

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Z	-	CLAY & GRAVEL	Surface	14
T	S	N	-	SANDROCK WHITE/BRN SOFT	14	52
Y	H	L	-	LIMEROCK BROWN/YELLOW HARD	52	145

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STL HVV 18.97 A53	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method PRES TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	52	17 S

9. Static Water Level
85 ft. below ground surface

10. Pump Test
Pumping level 110 ft. below surface
Pumping at 25 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TA		10-15-2013
Drill Rig Operator	Lic or Reg #	Date Signed
RL		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Building Overhang		50
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 12-13-2013 Updated On: 04-26-2022 Review Status: