

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WV354		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A			
Property Owner WALTON, RICHARD					Phone #				
Mailing Address 1962 30TH AVE					Town of RUSH RIVER				
City BALDWIN					State WI		Zip Code 54002		
County St. Croix		Co. Permit #		Notification # 49520203		Completed 10-15-2013		Subdivision Name	
								Lot #	
								Block #	
Well Constructor (Business Name) AUNE WELL DRILLING INC				Lic. # 95		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)	
								Method Code GPS008	
Address 1171 CNTY RD T HAMMOND WI 54015-4827				Well Plan Approval #		SE SW		Section Township	
				Approval Date (mm-dd-yyyy)		14 28 N		Range 17 W	
Hicap Permanent Well #		Common Well #		Specific Capacity 2		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
3. Well serves 1 # of				Hicap Well ? No					
Private, potable				Hicap Property ? No					
Heat Exchange ____ # of drillholes				Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE									
5. Drillhole Dimensions and Construction Method									
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole Lower Open Bedrock						
10	Surface	52	Rotary - Mud Circulation Rotary - Air <u>Yes</u> Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)						
6	52	105							
8. Geology									
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)	
-	-	Z	-	CLAY & GRAVEL		Surface		52	
-	B	L	-	BROKEN LIME		52		54	
-	-	L	-	LIME ROCK		54		105	
6. Casing, Liner, Screen									
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)		To (ft.)			
6	STL. HUV. 18.97 A53			Surface		54			
Dia. (in.)	Screen type, material & slot size			From (ft.)		To (ft.)			
7. Grout or Other Sealing Material									
Method									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement			
BENTONITE SLURRY		Surface		52		6 S			
9. Static Water Level									
50 ft. below ground surface									
10. Pump Test									
Pumping level 60 ft. below surface									
Pumping at 20 GP M for 2 Hrs.									
Pumping Method ?									
11. Well Is									
12 in. above grade									
Developed ? Yes									
Disinfected ? Yes									
Capped ? Yes									
12. Notified Owner of need to fill & seal ?									
Filled & Sealed Well(s) as needed?									
13. Constructor / Supervisory Driller						Lic #		Date Signed	
TA								10-15-2013	
Drill Rig Operator						Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Building Overhang		40
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-03-2014

Updated On: 02-03-2014

Review Status: