

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WV357		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner EVAN, JAROD						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 2433 30TH AVE								Town of EAU GALLE				2433									
City WOODVILLE						State WI		Zip Code 54028													
County St. Croix		Co. Permit #		Notification # 50176749		Completed 03-13-2014		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) AUNE WELL DRILLING INC				Lic. # 95		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.90223 °N -92.31293 °W				Method Code GPS008							
Address 1171 CNTY RD T HAMMOND WI 54015-4827				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 22 28 N 16 W				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		160		Yes Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam Yes Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T M C -		CLAY BROWN MEDIUM		Surface		45					
6		160		230						G H C -		CLAY GREY HARD		45		132					
4		230		280						T S C -		CLAY BROWN SOFT		132		158					
										Y H L -		LIMEROCK YELLOW HARD		158		280					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		170 ft. below ground surface				12 in. above grade							
6		STL HKK 18.97 PE-WELD ASTM A53				Surface		160		10. Pump Test Pumping level 220 ft. below surface Pumping at 30 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
4		STL HKK 10.79 PE WELD ASTM A53				40		230													
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement BENTONITE Surface 160 8 S														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller														Lic #		Date Signed					
TA																03-13-2014					
Drill Rig Operator														Lic or Reg #		Date Signed					
CB																03-13-2014					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	170	Building Overhang		30
			Septic or Holding, or POWTS Tank		170

Comment:

Created On: 07-10-2014

Updated On: 07-10-2014

Review Status: