

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WW114		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner M A B K G P N D LLC						Phone # (715)370-1267		1. Well Location				Fire # (if avail.)	
Mailing Address 303 RIM ROCK RD						Town of YORKVILLE							
City WAUSAU						State WI		Zip Code 54401					
County Racine		Co. Permit #		Notification # 46870218		Completed 02-28-2013		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) ASCHAUER E G & SONS INC				Lic. # 66		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.7046 °N -88.0472 °W			
Address PO BOX 206 KANSASVILLE WI 53139-0206				Well Plan Approval #		NW SW		Section 20		Township 3 N		Method Code GCD013	
						or Govt Lot #		Range 21 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 1.2				2. Well Type New Well			
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of OFFICE Non-community				Heat Exchange ___ # of drillholes		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) 6		From (ft.) Surface		To (ft.) 179		Upper Enlarged Drillhole				Lower Open Bedrock			
						Rotary - Mud Circulation				Rotary - Air			
						Rotary - Air & Foam				Drill-Through Casing Hammer			
						Reverse Rotary				Cable-tool Bit ___ in. dia...			
						Dual Rotary				Temp. Outer Casing ___ in. dia			
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
U - C -		BLUE CLAY		Surface		85							
- - X -		SAND & CLAY		85		102							
U - C -		BLUE CLAY		102		157							
- - P -		HARDPAN		157		172							
- - L -		LIMESTONE		172		179							
6. Casing, Liner, Screen													
Dia. (in.) 6		Material, Weight, Specification STEEL, 18.97LBS, A53B WHEATLAND, WELDED				From (ft.) Surface		To (ft.) 172					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material GRANULAR BENTONITE #8				From (ft.) Surface		To (ft.)		# Sacks Cement					
9. Static Water Level													
63 ft. below ground surface													
10. Pump Test													
Pumping level 80 ft. below surface													
Pumping at 20 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? NONE													
13. Constructor / Supervisory Driller													
MEA				Lic #		Date Signed 02-28-2013							
Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		34	Downspout/Yard Hydrant		34
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 04-08-2013

Updated On: 06-27-2019

Review Status: