Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WW115

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SHECTERLE, JACK	Phone #: (262)534-6770
Mailing Address: 23 N TEUT RD	
City: BURLINGTON	State: WI — Zip Code: 53105
County: Racine	Co. Permit #:
Notification #: 47587900	Completed: 05-20-2013
Well Constructor (Business Name): ASCHAUER E G & SONS INC	Lic. #: 66
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PO BOX 206 KANSASVILLE WI 53139-0206	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2	

1. Well Location

Village of ROCHESTER

Fire # (if avail.):

Street Address or Road Name and Number: 23 N TEUT RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 42.7126 °N -88.2413 °W

Method Code: GCD013

SE	SW	Section	Township	Range
or Govt Lot #		15	3 N	19 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

BAD CASING NOT TO CODE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	150

Upper Enlarged Drillhole — Lower Open Bedrock

Rotary - Mud Circulation .....

No — Rotary - Air ..... — Yes

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	20
-	-	X	-	SAND & CLAY	20	35
-	-	G	-	GRAVEL	35	43
-	-	X	-	SAND & CLAY	43	73
-	-	P	G	HARDPAN & STONES	73	94
-	-	L	-	LIMESTONE	94	150

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97 LBS., A53B WHEATLAND, WELDED	Surface	94
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 18 ft. below surface

Pumping at 20 GP M for 6 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

DONE BY PUMP INSTALLER MAAS & SONS

13. Constructor / Supervisory Driller	Lic #	Date Signed
MEA		05-30-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Wastewater Sump		40
Building Overhang		10	Sewer - Building Sanitary		40
Foundation Drain to Clearwater		10	Septic or Holding, or POWTS Tank		85

Comment:

Created On: 06-17-2013 Updated On: 06-28-2019 Review Status: