# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* WW316

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: PEPLINSKI, CHRIS | Phone # |
| Mailing Address: 3520 COACH LANTERN DR | |
| City: WISCONSIN RAPIDS | State: WI — Zip Code: 54494 |

| County | Co. Permit # | Notification # | Completed |
|---|---|---|---|
| Wood | | 44982975 | 07-23-2012 |

| Well Constructor (Business Name) | Lic. # | Facility ID # (Public Wells) |
|---|---|---|
| BRIAN M PATTEN | 6619 | |

Address: PATTEN ENTERPRISES LLC
ARKDALE WI 54613

| Hicap Permanent Well # | Common Well # | Specific Capacity |
|---|---|---|
| | | 1.9 |

**3. Well serves** 1 # of
Private,potable
Heat Exchange____# of drillholes

Well Plan Approval #
Approval Date (mm-dd-yyyy)
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

**1. Well Location**

| Town of GRAND RAPIDS | Fire # (if avail.) 3520 |
|---|---|

Street Address or Road Name and Number: COACH LANTERN DR

| Subdivision Name | Lot # | Block # |
|---|---|---|
| | | |

| Latitude / Longitude in Decimal Degree (DD) | Method Code |
|---|---|
| 44.3626 °N -89.7564 °W | GCD013 |

| NE NW or Govt Lot # | Section | Township | Range |
|---|---|---|---|
| | 26 | 22 N | 6 E |

**2. Well Type** Replacement
of previous unique well # AY65 constructed in 1988

Reason for replaced or reconstructed well ?
POOR VOLUME

Construction Type: Jetted

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 2 | Surface | 31 |
| 1.3 | 31 | 35 |

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

**8. Geology**

| Geology Codes | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|
| - - S - | SAND | Surface | 35 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 2 | WHEATLAND ERW | Surface | 31 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| 1.3 | CAMPBELL 80 GAUZE | 31 | 35 |

**7. Grout or Other Sealing Material**

Method

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| | Surface | | |

**9. Static Water Level**
13 ft. below ground surface

**10. Pump Test**
Pumping level 21 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

**11. Well Is**
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**12.** Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| BP | | 08-21-2012 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| | | |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance |
|---|---|---|
| Building Overhang | | 6 |

Comment:

Created On: 09-05-2012 Updated On: 05-05-2020 Review Status: