

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WW316		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner PEPLINSKI, CHRIS					Phone #			1. Well Location				Fire # (if avail.)				
Mailing Address 3520 COACH LANTERN DR								Town of GRAND RAPIDS				3520				
City WISCONSIN RAPIDS					State WI		Zip Code 54494					Street Address or Road Name and Number COACH LANTERN DR				
County Wood		Co. Permit #		Notification # 44982975			Completed 07-23-2012			Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) BRIAN M PATTEN				Lic. # 6619		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3626 °N -89.7564 °W				Method Code GCD013		
Address PATTEN ENTERPRISES LLC ARKDALE WI 54613				Well Plan Approval #				NE NW		Section 26		Township 22 N		Range 6 E		
				Approval Date (mm-dd-yyyy)				or Govt Lot #								
Hicap Permanent Well #			Common Well #			Specific Capacity 1.9			2. Well Type Replacement				of previous unique well # AY65 constructed in 1988			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? POOR VOLUME								
						Hicap Property ? No										
						Hicap Potable ?										
Construction Type Jetted																
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
2		Surface		31												
1.3		31		35		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
- - S -				SAND				Surface		35						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
2		WHEATLAND ERW				Surface		31								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
1.3		CAMPBELL 80 GAUZE				31		35								
7. Grout or Other Sealing Material																
Method																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement								
				Surface												
9. Static Water Level																
13 ft. below ground surface																
10. Pump Test																
Pumping level 21 ft. below surface																
Pumping at 15 GP M for 1 Hrs.																
Pumping Method ?																
11. Well Is																
18 in. above grade																
Developed ? Yes																
Disinfected ? Yes																
Capped ? Yes																
12. Notified Owner of need to fill & seal ?																
Filled & Sealed Well(s) as needed? Yes																
13. Constructor / Supervisory Driller																
BP				Lic #				Date Signed 08-21-2012								
Drill Rig Operator				Lic or Reg #				Date Signed								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		6

Comment:

Created On: 09-05-2012

Updated On: 05-05-2020

Review Status: