Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WW318

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SPEAR, CAROL	Phone #
Mailing Address: 1750 CO Z	
City: ARKDALE	State: WI — Zip Code: 54613
County: Adams	Co. Permit #: — Notification #: 45647251 — Completed: 09-24-2012
Well Constructor (Business Name): BRIAN M PATTEN	Lic. #: 6619 — Facility ID # (Public Wells):
Address: PATTEN ENTERPRISES LLC, ARKDALE WI 54613	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of STRONGS PRAIRIE				Fire # (if avail.): 1750
Street Address or Road Name and Number: CO Z				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.00253 °N -89.93191 °W				Method Code: OTH001
NE / SW or Govt Lot #:	Section: 29	Township: 18 N	Range: 5 E	

2. Well Type Replacement
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?: NO WATER
Construction Type: Jetted

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	52
1.3	52	56

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	15
-	-	C	-	CLAY	15	28
-	M	S	-	MED SAND	28	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ERW GALVINIZED THREADED	Surface	92
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.3	STAINLESS 80 GAUZE	92	96

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 42 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BP		09-29-2012
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang	>	10
			Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 10-18-2012 Updated On: 08-25-2022 Review Status: