Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WX117

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GONZALEZ, JERRY			Phone #
Mailing Address: 10730 N GAZEBO HILL PKWY E			
City: MEQUON	State: WI	Zip Code: 53092	
County: Ozaukee	Co. Permit #:	Notification #: 50114784	Completed: 12-02-2013

1. Well Location

City of MEQUON

Fire # (if avail.)

Street Address or Road Name and Number: 10730 N GAZEBO HILL PKWY E

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LIEBAU LAUN INC	527	

Address: 1200 W LIEBAU RD 124N
MEQUON WI 53092-3334

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Latitude / Longitude in Decimal Degree (DD): 43.214 °N -87.9574 °W

Method Code: GCD013

SE	NW	Section	Township	Range
or Govt Lot #		25	9 N	21 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.2

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	505

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

No — Rotary - Air ..... — Yes

Yes — Rotary - Air & Foam ..... — No

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	CLAY & STONES	Surface	140
-	-	P	-	HARD PAN	140	146
-	-	L	-	LIMESTONE	146	505

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53-B .280 EXL TUBE 18.97LBS/FT P.E. WELDED	Surface	146
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

110 ft. below ground surface

10. Pump Test

Pumping level 190 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	2	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
AL		12-03-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Foundation Drain to Clearwater		40
Clearwater Sump		50	Sewer - Building Sanitary		75

Comment:

Created On: 01-02-2014 Updated On: 07-15-2019 Review Status: