

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WX386		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LUND, LORRAINE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address E3782 HWY K						Town of WAUPACA						E3782			
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number E3782 HWY K			
County Waupaca		Co. Permit #		Notification # 6572821701		Completed 10-18-2016		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) NEAL D LOEHRKE				Lic. # 133		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3674 °N -89.0379 °W				Method Code GCD013	
Address VALLEY WELL DRILLING WEYAUWEGA WI 54983				Well Plan Approval #		SE NW		Section 22		Township 22 N		Range 12 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		2. Well Type Replacement				of previous unique well # constructed in					
Reason for replaced or reconstructed well ? UPDATE 2IN BASEMENT POINT				Hicap Well ? No		Hicap Property ? No		Hicap Potable ?		Construction Type Drilled					
Private, potable				Heat Exchange ___ # of drillholes											
3. Well serves 1 # of															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		73		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				No					
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S -				SAND				Surface		18					
- - C -				CLAY				18		59					
- N S U				FINE MUDDY SAND				59		63					
- - C -				CLAY				63		73					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL 18.97 LBS/FT A-53 GR B EXLTUBE WELDED				Surface		59							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		TELE STAINLESS 8 SLOT				59		63							
7. Grout or Other Sealing Material															
Method GRAVITY															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
CAVING SAND & DRILL CUTTINGS				Surface											
9. Static Water Level															
12 ft. below ground surface															
10. Pump Test															
Pumping level 41 ft. below surface															
Pumping at 12 GP M for 20 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
VALLEY WELL FILL SEAL 2IN															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
NDL						10-18-2016									
Drill Rig Operator				Lic or Reg #		Date Signed									
						10-18-2016									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-23-2017

Updated On: 05-08-2020

Review Status: