Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WX386

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LUND, LORRAINE	Phone #
Mailing Address: E3782 HWY K	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: 6572821701 — Completed: 10-18-2016
Well Constructor (Business Name): NEAL D LOEHRKE	Lic. #: 133 — Facility ID # (Public Wells):
Address: VALLEY WELL DRILLING, WEYAUWEGA WI 54983	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of WAUPACA	Fire # (if avail.): E3782
Street Address or Road Name and Number: E3782 HWY K	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3674 °N -89.0379 °W	Method Code: GCD013
SE NW or Govt Lot #: — Section: 22 — Township: 22 N — Range: 12 E	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: UPDATE 2IN BASEMENT POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	73

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	18
-	-	C	-	CLAY	18	59
-	N	S	U	FINE MUDDY SAND	59	63
-	-	C	-	CLAY	63	73

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LBS/FT A-53 GR B EXLTUBE WELDED	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELE STAINLESS 8 SLOT	59	63

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 41 ft. below surface

Pumping at 12 GP M for 20 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CAVING SAND & DRILL CUTTINGS	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

VALLEY WELL FILL SEAL 2IN

13. Constructor / Supervisory Driller	Lic #	Date Signed
NDL		10-18-2016
Drill Rig Operator	Lic or Reg #	Date Signed
		10-18-2016

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-23-2017 Updated On: 05-08-2020 Review Status: