

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WX387		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner COLLAR, MIKE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address N2634 EDGEWOOD DR						Town of MUKWA						N2634					
City NEW LONDON						State WI		Zip Code 54961				Street Address or Road Name and Number N2634 EDGEWOOD DR					
County Waupaca		Co. Permit #		Notification # 6432722001		Completed 07-15-2016		Subdivision Name ROLLING HILLS PLAT				Lot # 23		Block #			
Well Constructor (Business Name) NEAL D LOEHRKE				Lic. # 133		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3344 °N -88.7557 °W				Method Code GPS008			
Address VALLEY WELL DRILLING WEYAUWEGA WI 54983				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 36 22 N 14 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? MORE CAPACITY NEEDED									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.9		Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		265		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		No		T Q S S SAND T H C G HARDPAN COBBLES CLAY GRAVEL & STONES - - G - BOULDERS/ROCKS T H C G HARDPAN, COBBLES, CLAY, GRAVEL & STONES I H N - SANDSTONE		Surface 22 179 180 180 232 232 265		22 179 180 232 265			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface				20 in. above grade			
6		STEEL 18.97 LBS/FT A-53 GRADE B WELDED				Surface		232		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 16 ft. below surface Pumping at 15 GP M for 20 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method GRAVITY						Filled & Sealed Well(s) as needed? Yes											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		6IN FILL/SEAL REPORT ATTACHED									
CAVING SAND		Surface		20		S											
13. Constructor / Supervisory Driller						Lic #		Date Signed									
NDL								07-15-2016									
Drill Rig Operator						Lic or Reg #		Date Signed									
NDL								07-15-2016									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		11
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 09-29-2016

Updated On: 05-08-2020

Review Status: