

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WY389		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner REICHOFF, PAUL						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 1876 3RD AVE						Town of RICHFIELD						1876							
City COLOMA						State WI		Zip Code 54930				Street Address or Road Name and Number 3RD AVE							
County Adams		Co. Permit #		Notification # 49540830		Completed 10-28-2013		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) JOHN D ZOUSKI				Lic. # 6417		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.98553 °N -89.63627 °W				Method Code GPS008					
Address PO BOX 322 PLAINFIELD WI 54966				Well Plan Approval #		SW SW		Section 35		Township 18 N		Range 7 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 11.7		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NITRATES (MANURE CONTAMATED)													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.) 6		From (ft.) Surface		To (ft.) 176		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						Rotary - Mud Circulation				- - S -		SAND		Surface		54			
						Rotary - Air				- - Y -		SAND & GRAVEL		54		150			
						Rotary - Air & Foam				- S N -		SOFT SANDSTONE		150		157			
						<u>Yes</u> Drill-Through Casing Hammer				- H N -		HARD SANDSTONE		157		176			
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.) 6		Material, Weight, Specification IPSCO A53 6.625 X .280 WALL WELDED TOGETHER WEIGHT-2864.47				From (ft.) Surface		To (ft.) 151		24 ft. below ground surface				24 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
										Pumping level 27 ft. below surface Pumping at 35 GP M for 1 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement BENT ALONT CASING Surface												Filled & Sealed Well(s) as needed? Yes							
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JDZ						11-01-2013	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Building Overhang		7
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 11-15-2013

Updated On: 05-04-2020

Review Status: