Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WY397

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HIGGINS, STEPHANIE	Phone #: (715)310-7610
Mailing Address: 30 FERNDALE DR	
City: STEVENS POINT	State: WI Zip Code: 54481

County	Co. Permit #	Notification #	Completed
Portage		49376139	10-07-2013

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
JOHN D ZOUSKI	6417	

Address: PO BOX 322
PLAINFIELD WI 54966

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		7.5

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Village of PARK RIDGE

Fire # (if avail.): 30

Street Address or Road Name and Number: FERNDALE DR

Subdivision Name	Lot #	Block #
VIERTE IS 1ST	7	5

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.52148 °N -89.54697 °W	GPS008

SW	NW	Section	Township	Range
or Govt Lot #		34	24 N	8 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	77

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	35
-	-	Y	-	SAND & GRAVEL	35	77

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A53 6.625 X .280 WALL WELD TOGETHER WEIGHT-1403.78	Surface	74
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#12 SS ALLOY	74	77

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENT ALONG CASING	Surface		

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 32 ft. below surface
Pumping at 15 GP for 1 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDZ		10-11-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Foundation Drain to Sewer		45

Comment:

Created On: 11-04-2013 Updated On: 05-07-2020 Review Status: