

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WY397		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HIGGINS, STEPHANIE						Phone # (715)310-7610		1. Well Location				Fire # (if avail.)			
Mailing Address 30 FERNDAL DR						Village of PARK RIDGE						30			
City STEVENS POINT						State WI		Zip Code 54481				Street Address or Road Name and Number FERNDAL DR			
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #	
Portage				49376139		10-07-2013		VIERTE IS 1ST				7		5	
Well Constructor (Business Name) JOHN D ZOUSKI				Lic. # 6417		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.52148 °N -89.54697 °W				Method Code GPS008			
Address PO BOX 322 PLAINFIELD WI 54966				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 34 24 N 8 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW WELL							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5		Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
6		Surface		77		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
								- - S -		SAND		Surface		35	
								- - Y -		SAND & GRAVEL		35		77	
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is			
6		IPSCO A53 6.625 X .280 WALL WELD TOGETHER WEIGHT-1403.78				Surface		74		30 ft. below ground surface		20 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes			
6		#12 SS ALLOY				74		77		Pumping level 32 ft. below surface Pumping at 15 GP for 1 Hrs. Pumping Method ?		Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
BENT ALONG CASING				Surface											
13. Constructor / Supervisory Driller															
JDZ						Lic #		Date Signed							
Drill Rig Operator						Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Foundation Drain to Sewer		45

Comment:

Created On: 11-04-2013

Updated On: 05-07-2020

Review Status: