

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WY582		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ASPEN HOMES Phone # (262)695-4485						1. Well Location						Fire # (if avail.)	
Mailing Address 325 OAKTON AVE STE 202						Town of LISBON							
City PEWAUKEE State WI Zip Code 53072						Street Address or Road Name and Number W276 N8875 N FACE CT							
County Waukesha		Co. Permit #		Notification # 46801683		Completed 02-18-2013		Subdivision Name TWIN PINES			Lot # Block #		
Well Constructor (Business Name) MICHAEL G HARTMAN				Lic. # 436		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code		
Address MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NW Section Township Range or Govt Lot # 7 8 N 19 E		2. Well Type New Well of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 2		Reason for replaced or reconstructed well ? NEW CONSTRUCTION							
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		115									
5		115		118		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
- - Y -			SAND, GRAVEL			Surface			118				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		0.280 A 53 GRB WHEATLAND STEEL WELED				Surface		115					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		#18 SLOT COOK				115		118					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
CRUMBLES		Surface											
9. Static Water Level													
80 ft. below ground surface													
10. Pump Test													
Pumping level 90 ft. below surface Pumping at 20 GP M for 4 Hrs. Pumping Method ?													
11. Well Is													
12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No NO WELL													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
MH								02-26-2013					
Drill Rig Operator						Lic or Reg #		Date Signed					
MH								02-26-2013					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Foundation Drain to Clearwater		16
			Wastewater Sump		65
Building Overhang		15	Sewer - Building Sanitary		65
Clearwater Sump		65	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-25-2013

Updated On: 03-25-2013

Review Status: