

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WY583		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BADGER HOMES, SPOHRLEDER, BOB						Phone # (262)522-7094		1. Well Location				Fire # (if avail.)									
Mailing Address 1323 POPLAR DR						Town of OCONOMOWOC															
City WAUKESHA						State WI		Zip Code 53188													
County Waukesha		Co. Permit #		Notification # 46870909		Completed 02-18-2013		Subdivision Name				Lot # 1		Block #							
Well Constructor (Business Name) MICHAEL G HARTMAN				Lic. # 436		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code									
						Well Plan Approval #		°N		°W											
Address MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218						Approval Date (mm-dd-yyyy)		SW SE Section Township Range or Govt Lot # 18 8 N 17 E													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2		2. Well Type New Well				of previous unique well # constructed in									
Reason for replaced or reconstructed well ? NEW CONSTRUCTION																					
3. Well serves 1 # of Private, potable						Hicap Well ? No															
Heat Exchange ___ # of drillholes						Hicap Property ? No															
						Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		265		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								- - S - SAND Surface 40 - - P - HARDPAN 40 140 - - L - LIMESTONE 140 265							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		70 ft. below ground surface				12 in. above grade							
6		0.280 A 53 GRB WHEATLAND STEEL WELDED				Surface		140		10. Pump Test Pumping level 140 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method MOUNDED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
CRUMBLES				Surface																	
														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NO WELL							
13. Constructor / Supervisory Driller								Lic #		Date Signed											
MH										02-26-2013											
Drill Rig Operator								Lic or Reg #		Date Signed											
MH										02-26-2013											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Foundation Drain to Clearwater		16
			Wastewater Sump		50
Building Overhang		15	Sewer - Building Sanitary		65
Clearwater Sump		20	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-25-2013

Updated On: 03-25-2013

Review Status: