Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WZ282

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	KENAR, PAUL
Phone #	
Mailing Address	8553 RASCHER UNIT 1W
City	CHICAGO
State	IL
Zip Code	60656
County	Adams
Co. Permit #	
Notification #	52547142
Completed	08-19-2014
Well Constructor (Business Name)	TODD G ROOS
Lic. #	6287
Facility ID # (Public Wells)	
Address	BOX 223 OXFORD WI 53952
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	6

1. Well Location

Fire # (if avail.)	468
Town of JACKSON	
Street Address or Road Name and Number	FUR LN
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.73503 °N -89.6723 °W
Method Code	GPS006
NE SW or Govt Lot #	
Section	33
Township	15 N
Range	7 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of CAMPSITE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	120

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	G	SAND W/GRAVEL	Surface	54
-	-	C	-	CLAY	54	57
-	-	S	G	SAND W/GRAVEL	57	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 OD X .280 WALL A53B 18.97 LBS IPSCO	Surface	117
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	5 IN TEL 15 SLOT STAINLESS	117	120

9. Static Water Level

66 ft. below ground surface

10. Pump Test

Pumping level 69 ft. below surface

Pumping at 18 GP for 2 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		7 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
TTR		08-27-2014
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TTR		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: VACANT LOT

Created On: 10-01-2014 Updated On: 01-29-2015 Review Status: