

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WZ282		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KENAR, PAUL						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 8553 RASCHER UNIT 1W						Town of JACKSON						468	
City CHICAGO						State IL		Zip Code 60656				Street Address or Road Name and Number	
County Adams						Co. Permit #		Notification # 52547142				Completed 08-19-2014	
Well Constructor (Business Name) TODD G ROOS						Lic. # 6287		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.73503 °N -89.6723 °W	
Address BOX 223 OXFORD WI 53952						Well Plan Approval #		NE SW		Section 33		Township 15 N	
								Range 7 E		Block #			
Hicap Permanent Well #						Common Well #		Specific Capacity 6				Method Code GPS006	
3. Well serves 1 # of CAMPSITE						Hicap Well ? No		2. Well Type New Well				of previous unique well # constructed in	
Private, potable						Hicap Property ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled	
Heat Exchange ___ # of drillholes						Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		120									
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
-	-	S	G	SAND W/GRAVEL				Surface		54			
-	-	C	-	CLAY				54		57			
-	-	S	G	SAND W/GRAVEL				57		120			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		6.625 OD X .280 WALL A53B 18.97 LBS IPSCO				Surface		117					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
6		5 IN TEL 15 SLOT STAINLESS				117		120					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
#8 BENTONITE				Surface				7 S					
9. Static Water Level													
66 ft. below ground surface													
10. Pump Test													
Pumping level 69 ft. below surface													
Pumping at 18 GP for 2 Hrs.													
Pumping Method ?													
11. Well Is													
20 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? N/A													
13. Constructor / Supervisory Driller													
TTR				Lic #		Date Signed							
TTR						08-27-2014							
Drill Rig Operator				Lic or Reg #		Date Signed							
TTR													

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: VACANT LOT

Created On: 10-01-2014

Updated On: 01-29-2015

Review Status: