

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WZ287		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SPATH, KARL						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 8409 HWY 82						Town of OXFORD						8409									
City OXFORD						State WI		Zip Code 53952				Street Address or Road Name and Number HWY 82									
County Marquette		Co. Permit #		Notification # 55445850		Completed 10-05-2015		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) THOMAS D ROOS				Lic. # 249		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7811 °N -89.57843 °W				Method Code GPS006							
Address PO BOX 223 OXFORD WI 53952-0223				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 17 15 N 8 E				2. Well Type Replacement											
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 15		Reason for replaced or reconstructed well ? WANTED NEW 6 INCH WELL				Construction Type Drilled											
3. Well serves 1 # of Private, potable						Hicap Well ? No		Heat Exchange ___ # of drillholes													
						Hicap Property ? No															
						Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		98		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								- - C - CLAY - - S U MUDDY SAND - E S G CLEAN SAND W/GRAVEL		Surface 64 90 90		64 90 98			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				18 in. above grade							
6		6.625 OD X .280 WALL A53B PE 18.97# IPSCO				Surface		92		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 13 ft. below surface				Disinfected ? Yes							
5		6 IN TEL 15 SLOT STAINLESS				91		98		Pumping at 15 GP for 2 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method MOUNDED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes											
#8 BENTONITE				Surface				4 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														TDR						06-04-2015	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														TDR							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	52	Collector Sewer - San or Storm	>	100
Building Overhang		10	Sewer - Building Sanitary	>	12
			Septic or Holding, or POWTS Tank		28

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	WCR Submit Time	06/04/2015	THIS WELL WAS STARTED 060415 BUT WASN'T COMPLETED & HOOKED UP TO HOUSE UNTIL 100515.

Created On: 11-11-2015

Updated On: 02-23-2016

Review Status: