Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WZ288

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SCHIEBER, RUSSELL	Phone #
Mailing Address: 575 OAK RIDGE DR	
City: PORTAGE	State: WI / Zip Code: 53901
County: Marquette	Co. Permit #: / Notification #: 7096798701 / Completed: 03-09-2018
Well Constructor (Business Name): TODD G ROOS	Lic. #: 6287 / Facility ID # (Public Wells):
Address: BOX 223, OXFORD WI 53952	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity: 60

1. Well Location

Town of OXFORD	Fire # (if avail.): W7322
Street Address or Road Name and Number: W7322 FERN DR	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 43.79778 °N -89.52423 °W	Method Code: GPS008
NE SE or Govt Lot #:	Section: 10 / Township: 15 N / Range: 8 E

2. Well Type New Well
of previous unique well #: constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	462

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Yes Dual Rotary ..... No
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	90
-	-	Y	M	SILTY SAND & LIGHT GRAVEL	90	270
-	-	S	G	SAND W/LIGHT GRAVEL	270	333
-	-	C	-	CLAY	333	356
-	S	N	-	SOFT SANDSTONE	356	398
-	H	N	-	FIRM SANDSTONE	398	462

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 .280 WALL A53B PE 18.97	Surface	398
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
114 ft. below ground surface

10. Pump Test
Pumping level 115 ft. below surface
Pumping at 60 GP M for 10 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		6 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
TR		03-13-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	150	Building Overhang		36
			Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 05-07-2018 Updated On: 04-08-2020 Review Status: