Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WZ292

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRAKEBUSH, CHRIS	Phone #
Mailing Address: W678 FAWN AVE	
City: WESTFIELD	State: WI — Zip Code: 53964
County: Waushara	Co. Permit #: — Notification #: 55072081 — Completed: 04-29-2015
Well Constructor (Business Name): THOMAS D ROOS	Lic. #: 249 — Facility ID # (Public Wells):
Address: PO BOX 223 OXFORD WI 53952-0223	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 7.5

1. Well Location

Town of COLOMA			Fire # (if avail.): W1358
Street Address or Road Name and Number: W13589 S PLEASANT LAKE RD			
Subdivision Name: SUNSET POINT	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 43.98312 °N -89.5544 °W			Method Code: GPS006
SE SW or Govt Lot #:	Section: 33	Township: 18 N	Range: 8 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: PLUGGED POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	81

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	9
-	-	C	-	CLAY	9	13
-	-	S	G	SAND W/GRAVEL	13	60
-	E	Y	-	CLEAN SAND AND GRAVEL	60	81

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 OD X .280 WALL A53B 18.97 LBS PE IPSCO	Surface	78
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	6 IN TEL 12 SLOT STAINLESS	78	81

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		5 S

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 15 GP for 4 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TDR		04-29-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TDR		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	10	Sewer - Building Sanitary		20
			Septic or Holding, or POWTS Tank		16

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Separation Distance Variance	06/11/2015	<REQUIRED 50' TO SOIL ABSORPTION DRAIN FIELD & < 25' TO A SEPTIC TANK

Created On: 06-23-2015 Updated On: 08-06-2015 Review Status: