Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WZ299

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KOHNKE, GENE	Phone #
Mailing Address: W5694 CO J	
City: WESTFIELD	State: WI / Zip Code: 53964
County: Marquette	Co. Permit #: / Notification #: 55960860 / Completed: 07-28-2015
Well Constructor (Business Name): THOMAS D ROOS	Lic. #: 249 / Facility ID # (Public Wells):
Address: PO BOX 223, OXFORD WI 53952-0223	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity:

1. Well Location

Village of WESTFIELD	Fire # (if avail.): 239
Street Address or Road Name and Number: 4TH ST	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 43.88317 °N -89.48923 °W	Method Code: GPS006
SW NE or Govt Lot #:	Section: 12 / Township: 16 N / Range: 8 E

2. Well Type Replacement

of previous unique well #: / constructed in:

Reason for replaced or reconstructed well ?: PLUGGED TIGHT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	122

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	36
-	-	S	G	SAND W/LIGHT GRAVEL	36	39
		C		CLAY	39	85
		S		SAND	85	94
-	S	N	-	SOFT SANDSTONE	94	117
-	H	N	-	HARD SANDSTONE	117	122
-	S	N	-	SOFT SANDSTONE	122	122

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 OD .280 WALL A53B, 18.97LBS PE IPSCO	Surface	117
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	MIDWEST SAND BLOCKER	117	122

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		5 S

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 6 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

17 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TDR		07-28-2015
Drill Rig Operator	Lic or Reg #	Date Signed
TDR		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	16	Collector Sewer - San or Storm	>	100
			Sewer - Building Sanitary	>	25

Comment: 20'4" F-480 TAIL PIPE ATTACHED TO SCREEN 6" X 4" K-PACKERS

Created On: 09-04-2015 Updated On: 04-08-2020 Review Status: