

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WZ299		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KOHNKE, GENE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address W5694 CO J						Village of WESTFIELD						239					
City WESTFIELD						State WI		Zip Code 53964				Street Address or Road Name and Number					
County Marquette						Co. Permit #		Notification # 55960860		Completed 07-28-2015		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) THOMAS D ROOS						Lic. # 249		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.88317 °N -89.48923 °W		Method Code GPS006			
Address PO BOX 223 OXFORD WI 53952-0223						Well Plan Approval #		SW NE		Section 12		Township 16 N		Range 8 E			
								or Govt Lot #									
Approval Date (mm-dd-yyyy)						2. Well Type Replacement											
Hicap Permanent Well #						Common Well #		Specific Capacity				of previous unique well # constructed in					
Reason for replaced or reconstructed well ?						PLUGGED TIGHT											
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes						Hicap Property ? No		Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
6		Surface		122		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
-	-	C	-	CLAY				Surface		36							
-	-	S	G	SAND W/LIGHT GRAVEL				36		39							
		C		CLAY				39		85							
		S		SAND				85		94							
-	S	N	-	SOFT SANDSTONE				94		117							
-	H	N	-	HARD SANDSTONE				117		122							
-	S	N	-	SOFT SANDSTONE				122		122							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		6.625 OD .280 WALL A53B, 18.97LBS PE IPSCO				Surface		117									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
4		MIDWEST SAND BLOCKER				117		122									
9. Static Water Level																	
6 ft. below ground surface																	
10. Pump Test																	
Pumping level 6 ft. below surface																	
Pumping at 15 GP M for 4 Hrs.																	
Pumping Method ?																	
11. Well Is																	
17 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
7. Grout or Other Sealing Material																	
Method MOUNDED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
#8 BENTONITE		Surface				5 S											
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed? Yes																	
13. Constructor / Supervisory Driller																	
Lic #																	
Date Signed																	
TDR																	
07-28-2015																	
Drill Rig Operator																	
Lic or Reg #																	
Date Signed																	
TDR																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	16	Collector Sewer - San or Storm	>	100
			Sewer - Building Sanitary	>	25

Comment:

20'4" F-480 TAIL PIPE ATTACHED TO SCREEN 6" X 4" K-PACKERS

Created On: 09-04-2015

Updated On: 04-08-2020

Review Status: