

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WZ300		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MISZCZYSZYN, BOLESŁAW						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 307 ELM ST						Town of STRONGS PRAIRIE						1624	
City PROSPECT HEIGHTS						State IL		Zip Code 60070				Street Address or Road Name and Number	
CREE DR ARKDALE WI						Subdivision Name				Lot #		Block #	
County Adams		Co. Permit #		Notification # 55587961		Completed 06-28-2015		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) TODD G ROOS				Lic. # 6287		Facility ID # (Public Wells)				44.03258 °N -89.88218 °W		GPS008	
Address BOX 223 OXFORD WI 53952				Well Plan Approval #		SW NE		Section 15		Township 18 N		Range 5 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well			
Reason for replaced or reconstructed well ?													
3. Well serves 1 # of BARN				Hicap Well ? No		Private, potable				Hicap Property ? No		Construction Type Drilled	
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		161		Rotary - Mud Circulation							
						Rotary - Air							
						Rotary - Air & Foam							
						<u>Yes</u> Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
- - S -				SAND				Surface		14			
- - C -				14-22 CLAY				14		22			
- - S -				SAND				22		51			
- - Y U				MUDDY SAND LGT GRAVEL				51		103			
- S N -				SOFT SANDSTONE				103		138			
- H N -				HARD SANDSTONE				138		161			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		6.625 OD X .280 WALL A53B PE 18.97 # IPSCO				Surface		138					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
#8 BENTONITE MOUNDED				Surface				6 S					
9. Static Water Level													
34 ft. below ground surface													
10. Pump Test													
Pumping level 34 ft. below surface													
Pumping at 30 GP M for 4 Hrs.													
Pumping Method ?													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
TOR				07-28-2015									
Drill Rig Operator				Lic or Reg #				Date Signed					
TOR													

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance
Animal Yard - Include Hutches	>	50

Comment:

Created On: 09-04-2015

Updated On: 05-04-2020

Review Status: