Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WZ300

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MISZCZYSZYN, BOLESLAW	Phone #
Mailing Address: 307 ELM ST	
City: PROSPECT HEIGHTS	State: IL — Zip Code: 60070

County	Co. Permit #	Notification #	Completed
Adams		55587961	06-28-2015

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
TODD G ROOS	6287	

Address: BOX 223
OXFORD WI 53952

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity

3. Well serves 1 # of BARN
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of STRONGS PRAIRIE

Fire # (if avail.): 1624

Street Address or Road Name and Number: CREE DR ARKDALE WI

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.03258 °N -89.88218 °W	GPS008

SW NE or Govt Lot #	Section	Township	Range
	15	18 N	5 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	161

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	14
-	-	C	-	14-22 CLAY	14	22
-	-	S	-	SAND	22	51
-	-	Y	U	MUDDY SAND LGT GRAVEL	51	103
-	S	N	-	SOFT SANDSTONE	103	138
-	H	N	-	HARD SANDSTONE	138	161

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 OD X .280 WALL A53B PE 18.97 # IPSCO	Surface	138
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE MOUNDED	Surface		6 S

9. Static Water Level
34 ft. below ground surface

10. Pump Test
Pumping level 34 ft. below surface
Pumping at 30 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TOR		07-28-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TOR		

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
Animal Yard - Include Hutches	>	50

Comment:

Created On: 09-04-2015 Updated On: 05-04-2020 Review Status: