Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XA199

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRAUSE, MARK	Phone #: (920)427-6343
Mailing Address: N5874 HORSHOE RD	
City: HORICON	State: WI — Zip Code: 53032
County: Dodge	Co. Permit #:
Notification #: 49498074	Completed: 11-19-2013
Well Constructor (Business Name): CENTRAL WELL DRILLING INC	Lic. #: 4231
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PO BOX 405 400 S WOODWARD ST BRANDON WI 53919-0405	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.1	

1. Well Location

Town of HUBBARD	Fire # (if avail.): N5874
Street Address or Road Name and Number: W HORSESHOE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.4062 °N -88.6267 °W	Method Code: GCD013
NW SE or Govt Lot #:	Section: 19 — Township: 11 N — Range: 16 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of GREENHOUSE
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.8	Surface	114
6	114	253

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation ..... — No
- No / Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Z	G	CLAY, GRAVEL, BOULDERS	Surface	113
-	-	L	-	LIMEROCK	113	253

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL ASTM A-53B P.EL. USA EXL-TUBE	Surface	114
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
92 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 30 GP M for 0.5 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD & CUTTINGS	Surface	114	S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
SS		11-19-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Type	Qualifier	Distance
Building Overhang	>	30
Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 01-02-2014 Updated On: 10-01-2019 Review Status: