Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XB292

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ALEXANDER, NANCY			Phone #
Mailing Address: 425 SUNSTIEN RD			
City: EAGLE RIVER	State: WI	Zip Code: 54521	
County: Vilas	Co. Permit #:	Notification #: 51286701	Completed: 05-07-2014

Well Constructor (Business Name): ARTHUR (BUTCH) P SIMAC	Lic. #: 4084	Facility ID # (Public Wells):	
Address: PO BOX 961 EAGLE RIVER WI 54521-0961		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of LINCOLN

Fire # (if avail.): 425

Street Address or Road Name and Number: 425 SUNSTIEN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.8761 °N	-89.25302 °W			GPS008
SW SW or Govt Lot #	Section: 9	Township: 39 N	Range: 10 E	

2. Well Type Replacement
of previous unique well # OM764 constructed in

Reason for replaced or reconstructed well ?
PLUGGED UP

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia.	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	STEEL	Surface	47
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	10 SLOT	43	47

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	47

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 31 ft. below surface
Pumping at 7 GP M for 8 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BS		05-07-2014
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BS		05-07-2014

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Building Overhang		4
			Septic or Holding, or POWTS Tank		45

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	08/03/2020	NEAT CEMENT 0-47FT (8 GAL)	NO WATER

Created On: 06-20-2014 Updated On: 11-12-2021 Review Status: