# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* XB293

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | | | |
|---|---|---|---|
| Property Owner: WELCH, MIKE | | | Phone # |
| Mailing Address: 4327 DAISY LN | | | |
| City: EAGLE RIVER | State: WI | Zip Code: 54521 | |
| County: Vilas | Co. Permit #: | Notification #: 50125095 | Completed: 11-26-2013 |

| | | | |
|---|---|---|---|
| Well Constructor (Business Name): ARTHUR (BUTCH) P SIMAC | Lic. #: 4084 | Facility ID # (Public Wells): | |
| Address: PO BOX 961<br>EAGLE RIVER WI 54521-0961 | | Well Plan Approval #: | |
| | | Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: | Specific Capacity: | |

**3. Well serves** 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

**1. Well Location**

| | | | | |
|---|---|---|---|---|
| Town of LINCOLN | | | | Fire # (if avail.): 4327 |
| Street Address or Road Name and Number: 4327 DAISY LN | | | | |
| Subdivision Name: | | Lot #: | | Block #: |
| Latitude / Longitude in Decimal Degree (DD): 45.90355 °N -89.2294 °W | | | | Method Code: GPS008 |
| SW SE or Govt Lot # | Section: 34 | Township: 40 N | Range: 10 E | |

**2. Well Type** Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
PLUGGED POINT
Construction Type Driven Point

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

Upper Enlarged Drillhole / Lower Open Bedrock
- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

**6. Casing, Liner, Screen** — Removed? ____depth ft. (If NO explain on back side)

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 2 | STEEL | Surface | 32 |
| **Dia. (in.)** | **Screen type, material & slot size** | **From (ft.)** | **To (ft.)** |
| 2 | 10 SLOT | 28 | 32 |

**7. Grout or Other Sealing Material**
Method

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| | Surface | | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| - | - | S | - | SAND | Surface | 32 |

**9. Static Water Level**
16 ft. below ground surface

**10. Pump Test**
Pumping level 16 ft. below surface
Pumping at 8 GP M for 12 Hrs.
Pumping Method ?

**11. Well Is**
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**12.** Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| BS | | 11-26-2013 |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| BS | | 11-26-2013 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS dispersal component (soil absorption unit or mound) | | 100 | Building Overhang | | 6 |
| | | | Septic or Holding, or POWTS Tank | | 75 |

Comment:

Created On: 01-02-2014 Updated On: 06-30-2020 Review Status: