

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XC370		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SCHEIBNER, ERICH						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address N34 W32891 LAKEVIEW DR						Village of NASHOTAH															
City NASHOTAH						State WI		Zip Code 53058													
County Waukesha		Co. Permit #		Notification # 50281709		Completed 12-20-2013		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) PAUL F KUCK				Lic. # 6875		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.08293 °N -88.40092 °W				Method Code GPS008							
Address KUCK WELL DRLG & PUMP SERV NEOSHO WI 53059				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 8 7 N 18 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? EXISTING WELL PUMPING SILT / LOW YIELD													
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		Construction Type Drilled															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		7		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - C G		CLAY/GRAVEL MIX		Surface		7					
6		7		90						K - I -		BLACK TOPSOIL		7		9					
										T - G P		BROWN GRAVEL W/HARDPAN		9		73					
										G - C -		GRAY CLAY		73		79					
										T - G -		GRAY/BROWN GRAVEL		79		90					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				12 in. above grade							
6		19.45 .280 T/C ASTM A53 WHEATLAND				Surface		87		10. Pump Test Pumping level 42 ft. below surface Pumping at 15 GP for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
6		TELESCOPING SS 25 SLOT W/K-PACKER				87		90													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Method																					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
SAND/CLAY SLURRY W/BENTONITE CRUMBLES		Surface		7																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														PFK						12-20-2013	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														PFK						12-20-2013	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		14	Collector Sewer - San or Storm		70
Clearwater Sump		32	Foundation Drain to Clearwater		14
			Sewer - Building Sanitary		35

Comment:

Created On: 01-21-2014

Updated On: 07-12-2019

Review Status: