Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XC778

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLER, NORVAL	Phone #: (608)637-8375
Mailing Address: S5820 HWY 27	
City: VIROQUA	State: WI Zip Code: 54665
County: Vernon	Co. Permit #:
Notification #: 46871407	Completed: 02-21-2013
Well Constructor (Business Name): KOUBA WELL DRILLING INC	Lic. #: 376
Facility ID # (Public Wells):	
Address: PO BOX 444 HILLSBORO WI 54634	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of FRANKLIN	Fire # (if avail.): S5820
Street Address or Road Name and Number: HWY 27	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 43.5191 °N -90.871 °W	Method Code: GCD013
SE NE or Govt Lot #:	Section: 17 Township: 12 N Range: 4 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: OLD WELL CAVED IN

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	210
6	210	265

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes Rotary - Air & Foam ..... No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? 6depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	6
-	-	L	-	LIMESTONE	6	35
-	-	C	-	VOID	35	37
-	-	L	-	LIMESTONE	37	186
T	-	N	-	BROWN SANDSTONE	186	265

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLAINED STEEL WELDED IPSCO CASING A53 B18.97 LBS/FT .280 WALL 6INCH DRIVE SHOE	Surface	210
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: PRESSURE GROUTED W/1INCH TREMIES OUTSIDE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEET CEMENT STEP GROUT 5 HOLE PLUG IN SEMENT	Surface	210	125 S

9. Static Water Level

184 ft. below ground surface

10. Pump Test

Pumping level 245 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDO		02-27-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BV		02-21-2013

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		13

Comment: K. CAHOW-SCHOLTES GAVE PERMISSION ON 2/28/13 TO USE BENTONITE CHIPS.

Created On: 04-08-2013 Updated On: 04-29-2020 Review Status: