

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XC779		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SHETLER, EDDIE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 20874 JUPITER						Town of CLIFTON						20874					
City TOMAH						State WI		Zip Code 54660				Street Address or Road Name and Number JUPITER					
County Monroe		Co. Permit #		Notification # 46893546		Completed 02-26-2013		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) KOUBA WELL DRILLING INC				Lic. # 376		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8737 °N -90.3934 °W				Method Code GCD013			
Address PO BOX 444 HILLSBORO WI 54634				Well Plan Approval #		SE SE		Section 8		Township 16 N		Range 1 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		2. Well Type New Well						of previous unique well # constructed in					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?						Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Property ? No								Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		42		Rotary - Mud Circulation				- - C -		CLAY		Surface		15	
6		42		85		<u>Yes</u> Rotary - Air		<u>No</u>		T - N -		BROWN SANDSTONE		15		63	
						Rotary - Air & Foam				I - N -		WHITE SANDSTONE		63		85	
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						<u>Yes</u> Temp. Outer Casing 10in. dia											
						<u>Yes</u> Removed? 14depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface		20 in. above grade					
6		NEW PLAINED STEEL WELDED WHEATLAND CASING A53B 18.97LBS/FT. 280 WALL 6INCH DRIVE SHOE				Surface		42		10. Pump Test		Developed ? Yes					
										Pumping level 65 ft. below surface		Disinfected ? Yes					
										Pumping at 30 GP M for 1 Hrs.		Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method PRESSURE GROUTED W/1INC TREMIES OUTSIDE												Filled & Sealed Well(s) as needed? Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
NEET CEMENT		Surface		42		14 S											
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												JDO				02-27-2013	
												Drill Rig Operator		Lic or Reg #		Date Signed	
												BV				02-26-2013	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8

Comment:

Created On: 04-08-2013

Updated On: 04-29-2020

Review Status: