Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XC779

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SHETLER, EDDIE			Phone #
Mailing Address: 20874 JUPITER			
City: TOMAH	State: WI	Zip Code: 54660	
County: Monroe	Co. Permit #:	Notification #: 46893546	Completed: 02-26-2013

1. Well Location

Town of CLIFTON

Fire # (if avail.): 20874

Street Address or Road Name and Number: JUPITER

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
KOUBA WELL DRILLING INC	376	

Latitude / Longitude in Decimal Degree (DD): 43.8737 °N -90.3934 °W

Method Code: GCD013

Well Plan Approval #:

Address: PO BOX 444
HILLSBORO WI 54634

Approval Date (mm-dd-yyyy):

SE or Govt Lot #	SE	Section: 8	Township: 16 N	Range: 1 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	42
6	42	85

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 14depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	15
T	-	N	-	BROWN SANDSTONE	15	63
I	-	N	-	WHITE SANDSTONE	63	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLAINED STEEL WELDED WHEATLAND CASING A53B 18.97LBS/FT. 280 WALL 6INCH DRIVE SHOE	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: PRESSURE GROUTED W/1INC TREMIES OUTSIDE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEET CEMENT	Surface	42	14 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDO		02-27-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BV		02-26-2013

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8

Comment:

Created On: 04-08-2013 Updated On: 04-29-2020 Review Status: