Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XC781

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CAP, COULEE	Phone #
Mailing Address: 110 N MAIN	
City: WESTBY	State: WI — Zip Code: 54667
County: Crawford	Co. Permit #: — Notification #: 47023405 — Completed: 03-13-2013
Well Constructor (Business Name): KOUBA WELL DRILLING INC	Lic. #: 376 — Facility ID # (Public Wells):
Address: PO BOX 444 HILLSBORO WI 54634	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #:	Specific Capacity: 0.4

1. Well Location

Town of SENECA				Fire # (if avail.): 55305
Street Address or Road Name and Number: STONEY POINT RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 43.2922 °N -90.9697 °W				Method Code: GCD013
NW / NE or Govt Lot #:		Section: 33	Township: 10 N	Range: 5 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	210
6	210	285

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 4depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	4
T	-	N	-	BROWN SANDSTONE	4	22
-	-	L	-	LIMESTONE	22	160
T	-	N	-	BROWN SANDSTONE	160	240
T	-	H	-	BROWN SHALE	240	255
I	-	N	-	WHITE SANDSTONE	255	285

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLAINED STEEL WELDED WHEATLAND CASING A53B 18.97LBS/FT .280 WALL 6INCH DRIVE SHOE	Surface	210
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE GROUTED W/1INCH TREMIES OUTSIDE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEET CEMENT	Surface	210	115 S

9. Static Water Level
195 ft. below ground surface

10. Pump Test
Pumping level 265 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
23 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JDO		03-14-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BV		03-14-2013

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		45

Comment:

Created On: 04-08-2013 Updated On: 04-22-2020 Review Status: