

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XC781		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner CAP, COULEE						Phone #															
Mailing Address 110 N MAIN						1. Well Location						Fire # (if avail.)									
City WESTBY						State WI		Zip Code 54667				Town of SENECA		55305							
County Crawford						Co. Permit #		Notification # 47023405				Completed 03-13-2013		Street Address or Road Name and Number STONEY POINT RD							
Well Constructor (Business Name) KOUBA WELL DRILLING INC						Lic. # 376		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2922 °N -90.9697 °W		Method Code GCD013							
Address PO BOX 444 HILLSBORO WI 54634						Well Plan Approval #				NW NE Section Township Range or Govt Lot # 33 10 N 5 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		210		Rotary - Mud Circulation Rotary - Air <u>Yes</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 4depth ft. (If NO explain on back side)				- - C -		CLAY		Surface		4					
6		210		285						T - N -		BROWN SANDSTONE		4		22					
										- - L -		LIMESTONE		22		160					
										T - N -		BROWN SANDSTONE		160		240					
										T - H -		BROWN SHALE		240		255					
										I - N -		WHITE SANDSTONE		255		285					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		195 ft. below ground surface				23 in. above grade							
6		NEW PLAINED STEEL WELDED WHEATLAND CASING A53B 18.97LBS/FT .280 WALL 6INCH DRIVE SHOE				Surface		210		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 265 ft. below surface Pumping at 25 GP M for 1 Hrs. Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method PRESSURE GROUTED W/1INCH TREMIES OUTSIDE																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes							
NEET CEMENT				Surface		210		115 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														JDO				03-14-2013			
														Drill Rig Operator		Lic or Reg #		Date Signed			
														BV				03-14-2013			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		45

Comment:

Created On: 04-08-2013

Updated On: 04-22-2020

Review Status: