Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XE215

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KOTH, STEVE			Phone #: (715)496-3336
Mailing Address: 3860 CARDINAL DR			
City: STEVENS POINT	State: WI	Zip Code: 54482	
County: Portage	Co. Permit #:	Notification #: 6943601601	Completed: 09-08-2017

Well Constructor (Business Name): PETER LASKOWSKI	Lic. #: 4789	Facility ID # (Public Wells):	
Address: CHETS PLBG & HTG INC STEVENS POINT WI 54481-5670		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of PLOVER

Fire # (if avail.): 3860

Street Address or Road Name and Number: 3860 CARDINAL DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.48043 °N	-89.51721 °W			GPS008

NW NE or Govt Lot #	Section	Township	Range
	14	23 N	8 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NO WATER

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

6. Casing, Liner, Screen — Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	STEEL	Surface	26
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	ST ST 10 SLOT	26	29

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	29

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level _____ ft. below surface
Pumping at _____ GP for _____ Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SL		09-08-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Drain - Sanitary		12
Building Overhang		1
Sewer - Building Sanitary		28
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 10-09-2017 Updated On: 05-07-2020 Review Status: